

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Reporting Requirements Not Met for Coons Run PSD WV3301706

Our water system violated drinking water monitoring requirements. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation.

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During periods listed in the table below, we did not monitor or test as required and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

At this time, there is nothing you need to do.

The table below lists the monitoring we did not conduct, other violations, and the associated compliance period.

Monitoring Violation	Year-Fed Report #	Monitoring Frequency	Compliance Period
03, MONITORING, ROUTINE MAJOR Coliform (PRE-TCR) Results Not Submitted	FY1984 - 21684 FY1986 - 69185	Quarterly	Jan - Mar 1984 Jul - Sep 1985
23, MONITORING (TCR), ROUTINE MAJOR Valid Compliance Total Coliform Sample(s) Not Received	FY1992 - 103591 FY1992 - 144191	Monthly	Jun 1991 Aug 1991
24, COLIFORM, Results Not Reported as Required	FY1992 - 144291	Monthly	Jul 1991
36, MONITORING, RTN/RPT MAJOR, CHLORINE Missing Required Chlorine Residual Associated With a Bacteriological Sample or Entry Point to the Distribution	FY2026 - 598579	Monthly	Aug 2025
3A, MONITORING, ROUTINE, MAJOR (RTCR) Valid Compliance Total Coliform Sample(s) Not Reported	FY2026 - 598577	Monthly	Aug 2025
WB, CHLORINE, MOR Incomplete/Not submitted as Required or Missing Res. CI from Coliform Result	FY2026 - 598578	Monthly	Aug 2025
21, MCL (TCR) ACUTE	FY1998 - 123098	Monthly	Feb 1998

What happened? What is being done? (Describe corrective action)

Violations 03,23,24 & 21: Greater Harrison County PSD took over 2019. Violations 36, 3A WB: July 2025

Coons Run PSD was ordered by WV Office of Environmental Health to begin collecting two (2) compliance Bac-T's per month. Not all technicians were aware of this change.

For more information, please contact Julia Childers at 304-745-3463
(Contact Name) (Phone Number)
or 151 Peninsula Park Ave. West Milford WV 26451
(Mailing Address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Prepared: October 23, 2025

Date Distributed 11-17-25