

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

FAILURE TO COMPLETE CORRECTIVE ACTIONS

GREATER HARRISON PSD VALLEY OF GOOD HOPE, WV3301727

Our water system violated State drinking water requirement. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation (See table below).

An on-site evaluation of our system is conducted on a regular basis. Results of the evaluation show significant deficiencies in our water system which must be addressed to the Office of Environmental Health Services-District Office. We did not correct these deficiencies by the required date and are therefore in violation.

What should I do?

There is nothing you need to do at this time.

Required Corrective Action	Corrective Action Required by:
Failure to correct significant deficiencies	6/1/2025

What happened? What is being done? (Describe corrective action)

This is the District's response to the violation from the W.V.B.O.P.H. for the Valley of Good Hope Water System, PWSID#3301727. The violation noted was for the exterior condition of the paint on the tank as well as the access road to the tank site. At the time of the inspection the District was under a contract which was approved by W.V.B.O.P.H. The District is currently under construction on the water project. Construction of a new and larger tank will start in mid-August of this year 2025 with the completion anticipated by June of 2026.

For more information, please contact Greater Harrison Co. PSD at 304-745-3463
(Contact Name) (Phone Number)

or PO Box 190, West Milford, WV 26451
(Mailing Address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by GREATER HARRISON PSD VALLEY OF GOOD HOPE

State Water System ID# WV3301727

Date Distributed 8/7/25